



FESS FIRE
Fire Extinguisher Services (Pty) Ltd
COMPLETE FIRE PROTECTION

SUPREME INDUSTRIAL PARK UNIT F4
CNR SOUTHERN KLIPRIVIERSBERG ROAD
STEELDALE, JOHANNESBURG
2094

P.O.BOX 17050
DOORNFONTEIN
2028

TEL: (+27 11) 402 5063
Fax: (+27 11) 402 5080
E-MAIL: info@fessfire.co.za
WEBSITE: www.centa.co.za

Fire Extinguisher Services (Pty) Ltd
Reg. No. 1971/000018/07

LETTER OF COMPLIANCE

THIS LETTER SERVES TO STATE THAT IN OUR PROFESSIONAL OPINION BASED ON OUR INTERPRETATION OF EXISTING REGULATIONS, THE FIRE EXTINGUISHERS & HOSE REELS & SIGNS AT

ELIM CLINIC
PLANE ROAD
SPARTAN
KEMPTONPARK

HAVE BEEN SUPPLIED, INSTALLED AND MAINTAINED IN ACCORDANCE WITH SANS 1475 AND COMPLY WITH THE BASIC REQUIREMENTS OF THE FOLLOWING REGULATIONS:

SANS 10400 / SANS 10105 / SANS 1475
THE OCCUPATIONAL HEALTH AND SAFETY ACT OF 1993

AS SUCH, THE FIRE EXTINGUISHERS THROUGHOUT THE ABOVENAMED PREMISES SHOULD PROVIDE THE NECESSARY LEVEL OF FIRE PROTECTION, AND ARE SUITABLE FOR USE ON THE FOLLOWING:

CLASS A	Wood, Paper and Textile type Fires
CLASS B	Flammable Liquid and Gas type Fires
CLASS C	Fires in the presence of Live Electricity

MAINTENANCE AND UPGRADING OF THE FIRE EXTINGUISHERS MUST BE CARRIED OUT ON AN ANNUAL BASIS IN ORDER TO ENSURE CONTINUED COMPLIANCE WITH ONGOING CHANGES TO THE ABOVE REGULATIONS

FESS FIRE EXTINGUISHER SERVICED (PTY) LTD
HEREBY ASSURE YOU OF THE BEST ATTENTION AT ALL TIMES IN MATTERS RELATING TO FIRE PROTECTION, FIRE PREVENTION AND GENERAL SAFETY

K39873
OCTOBER 2023
DATE OF ISSUE

JABULANI MHLONGO
Name of qualified technician

18/177
SAQCC number

Note: In the view of the fact that certain sections of the regulations are open to interpretation, the local fire authorities may deem it necessary to insist on the installation of additional equipment.

